

## Wynland Water - 2020

Ten spyte van die inperking maatreels en beurtkrag kon watervoorsiening grootliks aangaan soos normaal.

In the Helderberg area, there were two unplanned interruptions due to problems that Cape Town experienced at the Faure Waterworks.



'n Hele paar kleiner pypbreke is deur die seisoen reggemaak.

Maintenance during the winter could proceed as planned.

Twee groot drukbeheer kleppe en 'n pomp beheerklep is oorgedoen.

Some pipe repairs takes some digging

Four smaller pumps as well as a VSD had to be replaced. Pumps ran more frequently than the previous year.

Heelwat kleiner elektriese probleme is by die pompstasies ondervind, vermoedelik as gevolg van Eskom se beurtkrag.



Replacements of some of the pipe fittings with S/S

Equipment theft and the vandalism that goes with it has increased drastically compared to the previous year.



Die beveiliging van ons toerusting bly steeds een van instandhouding se grootste uitdagings.

Faulty water meters and take off piping are replaced as needed throughout.

More and more air valves are being replaced on the scheme which are starting to leak due to age.



Despite desperate measures to secure our pump stations:



Toegang tot eiendom, veral in die nag, raak al hoe moeiliker en gevaarliker en in 'n noodgeval moet 'n afsluitkraan so vinnig moontlik bereik word.

Ons is steeds besig met die proses om afsluitkrane van hooflyne en damme om te skakel na elektriese aangedrywing (solar) met selfoon beheer.

Securing our equipment remains a priority

Daar is 60% van die totale toegelate water kwota gebruik.



At last some good news:



What an amazing sight!